



OLYMPIC VALLEY PUBLIC SERVICE DISTRICT



EXHIBIT G-2
4 Pages

WATER & SEWER OPERATIONS REPORT

DATE: October 31, 2023

TO: District Board Members

FROM: Brandon Burks, Operations Manager

SUBJECT: Operations & Maintenance Report for September 2023 – Information Only

BACKGROUND: The following is a discussion of the District’s operations from the month noted above. It also includes the maintenance activities performed by the Operations Department that are not the subject of a separate report. This report is formatted to provide new information and recent progress only.

DISCUSSION: Flow Report – September 2023

Water Production:		10.82 MG
Comparison:		1.11 MG more than 2022
Sewer Collection:		4.42 MG
Comparison:		0.36 MG more than 2022
Aquifer Level:	September 30, 2023:	6,186.3'
	September 30, 2022:	6,182.3'
	Highest Recorded:	6,192.0'
	Lowest Recorded:	6,174.0'
Creek Bed Elevation, Well 2:		6,186.9'
Precipitation:	September 2023:	0.78"
	Season to date total:	86.12"
	Season to date average:	523.54"
	% to year to date average:	160.86%

Flow Report Notes:

- The *Highest Recorded Aquifer Level* represents a rough average of the highest levels measured in the aquifer during spring melt period.

- The *Lowest Recorded Aquifer Level* is the lowest level recorded in the aquifer at 6,174.0 feet above mean sea level on October 5, 2001. This level is not necessarily indicative of the total capacity of the aquifer.
- The *Creek Bed Elevation* (per Kenneth Loy, West Yost Associates) near Well 2 is 6,186.9 feet.
- *Precipitation Season Total* is calculated from October 2022 through September 2023.
- The true *Season to date Average* could be higher or lower than the reported value due to the uncertainty of the Old Fire Station precipitation measurement during the period 1994 to 2004.
- In October 2011 the data acquisition point for the aquifer was changed from Well 2 to Well 2R.

Leaks and Repairs

Water

- The District issued nine leak/high usage notifications.
- Responded to zero after-hours customer service calls.

Sewer

- Responded to zero after-hours customer service calls.

Vehicles and Equipment

Vehicles

- Cleaned vehicles and checked inventory.

Equipment

- Cleaned equipment.

Operations and Maintenance Projects

1810 Olympic Valley Road (Old Fire Station)

- Inspected and tested the generator.
- General housekeeping.

305 Olympic Valley Road (Administration and Fire Station Building)

- Inspected and tested the generator.

Water System Maintenance

- Three bacteriological tests were taken in September: one at 1810 Olympic Valley Road, one at Everline Resort and one at Zone 3 Booster Station; All three samples were reported absent.
- Positive Coliform samples were reported in October. Everline Resort, Zone Three Booster Station and 3103 Sierra Crest Place were positive for coliform and negative for E.coli. All sites were repeat sampled and came back negative for coliform and E.coli. Chlorination of the entire system was implemented

under direction of California State Water Boards, Division of Drinking Water. System flushing is ongoing while the system is chlorinated as well.

- Leak detection services performed: two.
- Customer service turn water service on: zero.
- Customer service turn water service off: zero.
- Responded to zero customer service calls with no water.

Operation and Maintenance Squaw Valley Mutual Water Company

- Assisted new operators with transition.

Sewer System Maintenance

- Check for I and I issues.
- Sewer cleaning.

Telemetry

- The rainfall measurements for the month of September were as follows:
Nova Lynx: 0.78", Palisades Tahoe Snotel: 1.40".

Administration

- Monthly California State Water Boards report.

Services Rendered

- Underground Service Alerts (24)
- Pre-remodel inspections (0)
- Final inspections (0)
- Fixture count inspections (0)
- Water service line inspections (3)
- Sewer service line pressure test (2)
- Sewer service line inspections (0)
- Sewer main line inspections (0)
- Water quality complaint investigations (0)
- Water Backflow Inspections (0)
- FOG inspections (0)
- Second Unit inspection (0)

Other Items of Interest

- Training – SDRMA Online class.

ATTACHMENTS: Monthly Water Audit Report

DATE PREPARED: October 18, 2023

Olympic Valley Public Service District - Monthly Water Audit Report

Audit Month: September Report Date: October 31, 2023 Performed By: Brandon Burks
 Year: 2023

Meter Reader: Jason McGathey Reading begin Date & Time: 10/2/23 8:30 AM
 Reading end Date & Time: 10/2/23 11:00 AM
 Total lag time: 2:30:00

Begin Audit Period: 8/31/23 12:00 AM
 End Audit Period: 10/2/23 12:00 AM

Total Metered Consumption for audit period specified (including hydrant meters): 8,713,365

Additional Consumption - Unmetered

Fire Department Use: 10,000
 Hydrant Flushing: 25,000
 Blow-Off Flushing: _____
 Sewer Cleaning: 10,000
 Street Cleaning: _____
 Well Flushing: _____
 Tank Overflows: _____
 Unread Meter Estimated Reads: _____
 Other: Hydrant meters _____
 Total Unmetered Consumption (for audit period specified): 45,000

Estimated Unknown Loss - Unmetered

Known Theft: _____
 Known Illegal Connections: _____
 Total Estimated leaks that have been repaired: 300,000
 Total Estimated Unmetered (for audit period specified): 300,000

Total Production for audit period specified: 11,739,344

Total Metered/Unmetered Consumption for audit period specified: 9,058,365

Total Water Loss (Production - Consumption): 2,680,979

Comments: The production totals are different than the monthly report due to a different time frame being used. The District continues to look for leaks. A large leak was found and repaired east of the stables in October.

* Note - All Production & Consumption Totals In U.S. Gallons *